

ADDENDUM NO. 2

TOWN OF STEVENSVILLE PARK AVENUE SEWER MAIN EXTENSION PROJECT HDR PROJECT NO. 10256142

HDR Engineering, Inc.
700 SW Higgins, Ste 200
Missoula, MT 59803
Phone: (406) 532-2219

PART 1 - GENERAL

1.01 SCOPE

A. This addendum forms a part of the Bidding and Contract Documents and modifies the Project Manual as described below.

B. This Addendum consists of 1 page.

1.02 ACKNOWLEDGEMENT

A. All bidders are required to base their bid upon the information furnished in this Addendum and acknowledge receipt of this Addendum by signing and dating in the space provided in the Bid Form.

PART 2 - PROJECT MANUAL

2.01 DIVISION 00 – PROCUREMENT AND CONTRACTING REQUIREMENTS

A. SECTION 00813 – SPECIAL PROVISIONS

1. To Section 00813, update MSP-23 Permit Requirements with the following addition:
 - i. (2) Contractor will be responsible for procuring an encroachment permit from the County prior to excavation work in County easements and Right of Ways.

PART 3 - PROJECT DRAWINGS

3.01 SHEET C-1

A. Sheet C-1, add the following to Keynote No. 4:

1. Provide at least 3 inches of asphalt and 4 inches of crushed concrete.